



WORKING PRESSURE
150 PSI COLD WORKING PRESSURE

TEST PRESSURE
1.5 TIMES COLD WORKING PRESSURE

- | | | | |
|----|-------------|----|-----------------|
| 1 | BODY | 7 | COVER BOLT |
| 2 | COVER | 8 | RETAINING SCREW |
| 3 | BAFFLE | 9 | GUIDE BUSHING |
| 4 | SEAT | 14 | PIPE PLUG |
| 5 | FLOAT | 20 | GUIDE SHAFT |
| 5L | LOWER FLOAT | 28 | PIPE PLUG |
| 6 | GASKET | 36 | PIPE PLUG |

SEE DRAWING NO. VM-301A-M FOR STANDARD MATERIALS OF CONSTRUCTION.
SEE DRAWING NO. VM-301ADISV-M FOR SUPER VALVE MATERIALS OF CONSTRUCTION.

WASTEWATER AIR/VACUUM VALVE

DATE 4-8-14

VAL-MATIC

VALVE AND MANUFACTURING CORP.

DRWG. NO.

VMC-301A